



**Clinton Johnson, Fire Marshal/Emergency Management Coordinator**  
**Carole Chambers, Secretary/Emergency Management Assistant**  
**James Nykaza, Inspector & Investigator**  
**John Gosselin, Public Education**  
**Phone: 281-446-4928**

## Fire Safety Related Permits and Inspection

**All plans are reviewed and permits issued by the Humble Building Department at 114 W. Higgins. The Building Department is open from 8 am to 5pm, Monday thru Friday and can be reached by telephone at 281 446 3061. Requests for inspection appointments should be made to the building department.**

### **Required Permits and Inspections:**

Vent Hood installation or revision in cooking establishments requires application for a mechanical permit. The mechanical permit covers installation or revision of *Fire Suppression Systems* associated with the Vent Hood. *Fire Suppression Systems shall be inspected prior to ceiling or wall cover and upon completion of work. A trip test is not required.*

Paint Spray Booth installation or revision requires application for a mechanical permit. The mechanical permit covers installation or revision of *Fire Suppression Systems* associated with the Vent Hood. *Fire Suppression Systems shall be inspected prior to ceiling or wall covering and upon completion of work. A trip test is not required.*

Fire Alarm installation or revision requires application for a building permit. If a building permit has been issued for new construction or revision of a building, fire alarm work is covered under that permit. *Fire Alarms shall be inspected upon completion of installation. The Fire Marshal or inspector will operationally test installed equipment and review installation plans at that time.*

Fire Sprinkler System installation or revision requires application for a Fire Sprinkler Permit. Fire Sprinkler permits are \$30.00 regardless of number of heads. Two sets of blueprints are required for review. (blue-prints are not required on re-fits of existing systems that affect fewer than 20 heads) It typically takes 2 to 4 days to complete review. Fire Sprinkler installers must provide a copy of their Texas Fire Marshal License to be issued a permit. *Fire Sprinkler System inspections are required:*

1. *Prior to cover of main supply piping*
2. *Prior to ceiling or wall covering*
3. *Upon completion of installation*

Fire Marshal witnessed hydrostatic testing at 200 psi for 2 hours is required on all new installation. Hydrostatic testing at 150 psi for 2 hours is required on all retrofits of existing systems when over 20 heads are affected.